

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF GREEN-TAYLOR WATER)	
DISTRICT FOR A DEVIATION FROM THE)	CASE NO.
REQUIREMENTS OF 807 KAR 5:066, SECTION)	2002-00298
4(4), REGARDING WATER STORAGE)	

O R D E R

On August 5, 2002, the Green-Taylor Water District ("Green-Taylor") applied for permission to deviate from Administrative Regulation 807 KAR 5:066, Section 4(4), which requires that each utility maintain minimum water storage of one day's supply of its average daily usage. Green-Taylor states in its application that its average daily water usage, including unaccounted-for water, is approximately 918,000 gallons, and that its current water storage capacity is 740,000 gallons.

The Commission, having reviewed the application and being otherwise sufficiently advised, finds that:

1. Green-Taylor is not in compliance with Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Because of the time needed to plan, finance, and construct water storage facilities, Green-Taylor should be given until January 1, 2005 to comply with Administrative Regulation 807 KAR 5:066, Section 4(4).

IT IS THEREFORE ORDERED that:

1. Green-Taylor is given until January 1, 2005 to comply with the provisions of Administrative Regulation 807 KAR 5:066, Section 4(4).
2. Green-Taylor shall take all necessary actions to bring its water storage facilities into compliance with Commission regulations prior to January 1, 2005.
3. Green-Taylor shall file with the Commission a report noting the status of the utility's efforts to comply with Commission regulation 807 KAR 5:066, Section 4(4), prior to January 1, 2004.

Done at Frankfort, Kentucky, this 16th day of October, 2002.

By the Commission

ATTEST:


Executive Director